



Product Service

Attestation of Conformity

No. N8A 075006 0078 Rev. 00

Holder of Certificate: **NOARK Electrics (Shanghai) Co., Ltd.**
No.3857 Sixian Road, Songjiang District
201614 Shanghai
PEOPLE'S REPUBLIC OF CHINA

Product: **Moulded case circuit breaker**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704102148702-00

Date, 2021-10-28

(Jie Zhu)



Product Service

Attestation of Conformity

No. N8A 075006 0078 Rev. 00

Model(s): Ex9M3HVS, Ex9M3HVN**Parameters:**

Rated insulation voltage U_i : 1250V
Rated impulse voltage U_{imp} : 12kV
Rated current I_n : 250A, 315A, 350A, 400A, 500A, 630A
Rated operational voltage U_e : AC800V, AC1000V, AC1150V
Rated service short-circuit breaking capacity I_{cs} : See table 1
Rated ultimate short-circuit breaking capacity I_{cu} : See table 1
Selectivity category: A
Rated frequency: 50/60Hz
Number of poles: 3P
Type of overcurrent release: Thermal-magnetic

Table 1

I_n (A)	U_e (V)	I_{cu} (kA)		I_{cs} (kA)	
		Ex9M3HVS	Ex9M3HVN	Ex9M3HVS	Ex9M3HVN
250, 315, 350, 400, 500, 630	AC800	36	50	36	50
	AC1000	25	35	15	20
	AC1150	10	10	10	10

**Tested
according to:**

EN 60947-2:2017/A1:2020