

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD  
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



Product Service

# Attestation of Conformity

No. N8A 075006 0049 Rev. 01

**Holder of Certificate:** **NOARK Electrics (Shanghai) Co., Ltd.**  
 No.3857 Sixian Road, Songjiang District  
 201614 Shanghai  
 PEOPLE'S REPUBLIC OF CHINA

**Product:** **Low voltage switchgear combination**  
**Low Voltage Circuit-breakers**

**Model(s):** **Ex9BP-JX**

**Parameters:**

Rated impulse withstand voltage:	4kV
Rated insulation voltage:	1000V
Rated voltage:	DC250V (1P in series), DC500V (2P in series), DC750V (3P in series), DC1000V (4P in series)
Rated current:	1A, 1.6A, 2A, 3A, 4A, 5A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A
Rated service short-circuit breaking capacity:	10kA
Rated ultimate short-circuit breaking capacity:	10kA
Selectivity category:	A

**Tested** EN 60947-2:2017

**according to:**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance.

It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:** 704101069904-02

Date, 2019-08-09 ( Lutz Langguth )

Page 1 of 1

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.