

TÜV SÜD  
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



Product Service

# CERTIFICATE

No. B 075006 0048 Rev. 01

**Holder of Certificate:** **NOARK Electrics (Shanghai) Co., Ltd.**

No.3857 Sixian Road, Songjiang District  
201614 Shanghai  
PEOPLE'S REPUBLIC OF CHINA

**Production Facility(ies):** 075006

**Certification Mark:**



**Product:** **Low voltage switchgear combination  
Low Voltage Circuit-breakers**

**Model(s):** **Ex9BP-JX**

**Parameters:**

Rated impulse withstand voltage:	4kV
Rated insulation voltage:	1000V
Rated voltage:	DC250V (1P in series), DC500V (2P in series), DC750V (3P in series), DC1000V (4P in series)
Rated current:	1A, 1.6A, 2A, 3A, 4A, 5A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A
Rated service short-circuit breaking capacity:	10kA
Rated ultimate short-circuit breaking capacity:	10kA
Selectivity category:	A

**Tested according to:** EN 60947-2:2017

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 704101069904-02

**Valid until:** 2024-08-08

**Date,** 2019-08-09 ( Lutz Langguth )