

强制性认证产品符合性自我声明



自我声明编号：2020980307001430

上海诺雅克电气有限公司（生产者）确认知晓《强制性产品认证自我声明实施规则》以及相关产品强制性认证实施规则的要求，对本声明承担全部法律责任。

上海诺雅克电气有限公司（生产者）声明以下产品已按照《强制性产品认证自我声明实施规则》以及相关产品强制性认证实施规则的要求进行检测，符合相关标准要求；自本声明签署之日起，生产和销售的产品持续符合以下标准与实施规则的要求；保存本声明涉及的技术文档至少10年；正确使用强制性产品认证标志；如产品或其符合性信息发生变更，将及时更新技术文档并报送产品变更信息。

生产者名称：上海诺雅克电气有限公司
生产者地址：上海市松江区思贤路3857号
依据的强制性产品认证规则：CNCA-00C-008：2019 强制性产品认证实施规则自我声明
产品名称：剩余电流保护断路器
产品系列、型号、规格：Ex9ML2；详见附件
依据的标准：GB/T 14048.2-2020
生产企业名称：上海诺雅克电气有限公司
生产企业地址：上海市松江区思贤路3857号

联系人：李然
电话：021-37791111
电子邮箱：li.ran@noark.cn
指定签字人：

自我声明时间：2023-07-06
自我声明地点：上海
生产者签章：



注：有关本声明信息真伪可登录全国认证认可信息公共服务平台（cx.cnca.cn）或扫描右上角二维码查询。

强制性认证产品符合性自我声明(附页)



自我声明编号: 2020980307001430

产品系列、型号、规格(附件):

Ex9ML2
Uimp: 8kV;
Ui: 1000V;
Ue: AC380/400/415V, AC440V;
In: 125A, 160A, 180A, 200A, 225A, 250A(TMU, Electromagnetic);
32A, 40A, 50A, 63A, 80A, 100A, 125A, 160A, 180A, 200A, 225A, 250A(ETU);
Over-current Release Type: TMU, Electromagnetic, ETU;
Ics=Icu:
AC380/400/415V: 35/50/70/100/150kA(S/N/Q)/H/P);
AC440V: 36/50/70/100/100kA(S/N/Q)/H/P);
Icw: electronic type: 1kA/1s(In≤63A), 2kA/1s(63A<In≤160A), 3kA/1s(In≥180A);
I-n: 0.03/0.05/0.1/0.2/0.3/0.5/1/2A. The eight gears are adjustable(0.03A is Non-delay type, the rest are non-delay, delay adjustable);
Rated residual operating current type: Type AC; Type A;
Rated current operating type: Electronic tripping;
I-m: 25%Icu;
Selectivity category: A;
Release level: 5, 10, 20 Adjustable(SU20LM, SU20SM);
Poles: 3P, 4P;
Suitable for isolation;
50/60Hz;
Auxiliary contacts and alarm contacts:
(Auxiliary contacts AX21, alarm contacts AL21, CQC Certificate number: CQC2019010304169161);
INOINC;
Ith: 5A;
AC-15: Ue/Ie: AC110V/5A, AC240V/4A, AC415V/2A;
DC-13: Ue/Ie: DC110V/0.25A, DC220V/0.25A;
Electronic attachments in accordance with Appendix N;
Under Voltage Release UVT22.
Us: AC48V 50/60Hz, AC110V 50/60Hz, AC220-240V 50/60Hz, AC380-415V 50/60Hz, DC24V, DC48V,
DC110-120V, DC220V;
Motor operator MOD22.
Us: AC110V 50/60Hz, AC220-240V 50/60Hz, AC380-415V 50/60Hz, DC24V, DC110V, DC220V

联系人: 李然
电话: 021-37791111
电子邮箱: li.ran@noark.cn
指定签字人:

自我声明时间: 2023-07-06

自我声明地点: 上海

生产者签章:



注: 有关本声明信息真伪可登录全国认证认可信息公共服务平台 (cx.cnca.cn) 或扫描右上角二维码查询。
第2页/共4页

强制性认证产品符合性自我声明(附页)



自我声明编号: 2020980307001430

产品系列、型号、规格(附件):

ExM12
Uimp: 8kV;
Ui: 1000V;
Ue: AC380/400/415V, AC440V;
In: 125A, 160A, 180A, 200A, 225A, 250A(热磁式, 电磁式);
32A, 40A, 50A, 63A, 80A, 100A, 125A, 160A, 180A, 200A, 225A, 250A(电子式);
过电流脱扣器类型: 热磁式, 电磁式, 电子式;
Ics=Icu:
AC380/400/415V: 36/50/70/100/150kA(S/N/Q/H/P);
AC440V: 36/50/70/100/100kA(S/N/Q/H/P);
Icw: 电子式: 1kA/1s(In≤63A), 2kA/1s(63A<In≤160A), 3kA/1s(In≥180A);
I_n: 0.03/0.05/0.1/0.2/0.3/0.5/1/2A(核可调)(0.03A为非延时型, 其余均为非延时, 延时可调);
脱扣剩余动作类型: AC型, A型;
漏电脱扣器类型: 电子式;
I_{om}: 25%Icu;
选择性类别: A;
脱扣曲线: 5, 10, 20可调(SU20LM, SU20SM);
极数: 3P, 4P;
适用于频率:
适用频率: 50/60Hz;
配用的辅助触头和报警触头:
(辅助触头AX21, 报警触头AL21, CQC证书编号: CQC2019010304169161);
1NO1NC;
Ith: 5A;
AC-15: Ue/le: AC110V/5A, AC240V/4A, AC415V/2A;
DC-13: Ue/le: DC110V/0.25A, DC220V/0.25A;
符合附录N的电子附件:
欠压脱扣器UVT22:
Us: AC48V 50/60Hz, AC110V 50/60Hz, AC220~240V 50/60Hz, AC380~415V 50/60Hz, DC24V,
DC48V, DC110~120V, DC220V;
电动操作机构MOD22:
Us: AC110V 50/60Hz, AC220~240V 50/60Hz, AC380~415V 50/60Hz, DC24V, DC110V, DC220V

联系人: 李然
电话: 021-37791111
电子邮箱: li.ran@noark.cn
指定签字人:

自我声明时间: 2023-07-06
自我声明地点: 上海
生产者签章:



强制性认证产品符合性自我声明(附页)

自我声明编号: 2020980307001430



产品系列、型号、规格(附件):

型号的解釋:
Ex 9 M L 2 ◦
Ex: 企业特征代号
9: 企业设计序号
M: 塑料外壳式断路器代号
L: 剩余电流模块代号
2: 壳架等级电流: 2表示250A
◦: 分断能力代号: S, N, Q, H, P

联系人: 李然
电话: 021-37791111
电子邮箱: li.ran@noark.cn
指定签字人:

自我声明时间: 2023-07-06

自我声明地点: 上海

生产者签章

