

强制性认证产品符合性自我声明



自我声明编号: 2020980307001431

上海诺雅克电气有限公司(生产者) 确认知晓《强制性产品认证自我声明实施规则》以及相关产品强制性认证实施规则的要求, 对本声明承担全部法律责任。

上海诺雅克电气有限公司(生产者) 声明以下产品已按照《强制性产品认证自我声明实施规则》以及相关产品强制性认证实施规则的要求进行检测, 符合相关标准要求; 自本声明签署之日起, 生产和销售的产品持续符合以下标准与实施规则的要求; 保存本声明涉及的技术文档至少10年; 正确使用强制性产品认证标志; 如产品或其符合性信息发生变更, 将及时更新技术文档并报送产品变更信息。

生产者名称: 上海诺雅克电气有限公司
生产者地址: 上海市松江区思贤路3857号
依据的强制性产品认证规则: CNCA-00C-008: 2019 强制性产品认证实施规则自我声明
产品名称: 剩余电流保护断路器
产品系列、型号、规格: Ex9ML3; 详见附件
依据的标准: GB/T 14048.2-2020
生产企业名称: 上海诺雅克电气有限公司
生产企业地址: 上海市松江区思贤路3857号

联系人: 李然
电话: 021-37791111
电子邮箱: li.ran@noark.cn
指定签字人:

自我声明时间: 2023-07-06
自我声明地点: 上海

生产者签章:



强制性认证产品符合性自我声明(附页)



自我声明编号: 2020980307001431

产品系列、型号、规格(附件):

Ex9M3
Uimp: 12kV;
Ui: 1000V;
Ue: AC380/400/415V, AC440V;
In: 250A, 315A, 350A, 400A, 500A(热磁式, 电磁式); 250A, 315A, 350A, 400A, 500A, 630A(电子式);
过电流脱扣器类型: 热磁式, 电磁式, 电子式;
Ics=Icu:
AC380/400/415V: 36/50/70/100/150kA(S/N/Q/H/P);
AC440V: 36/50/70/100/100kA(S/N/Q/H/P);
Icw: 电子式: 5kA/1s(In≤400A), 8kA/1s(In≥500A);
I-n: 0.03/0.05/0.1/0.2/0.3/0.5/1/2A 八档可调(0.03A为非延时型, 其余均为非延时, 延时可调);
额定剩余动作类型: AC型, A型;
漏电脱扣器类型: 电子式;
I-m: 25%Icu;
选择性类别: A(热磁式, 电磁式), B(电子式);
脱扣级别: 5, 10, 20, 30可调(SU20LM, SU20SM);
极数: 3P, 4P;
适用于隔离;
适用频率: 50/60Hz;
配用的辅助触头和报警触头:
(辅助触头AX21, 报警触头AL21, CQC证书编号: CQC2019010304169161);
1NO1NC;
Ith: 5A;
AC-15: Ue/In: AC110V/5A, AC240V/4A, AC415V/2A;
DC-13: Ue/In: DC110V/0.25A, DC220V/0.25A;
符合附录N的电子附件:
欠压脱扣器UV722:
Us: AC48V 50/60Hz, AC110V 50/60Hz, AC220-240V 50/60Hz, AC380-415V 50/60Hz, DC24V, DC48V, DC110-120V, DC220V;
分励脱扣器SHT22:
Us: AC48V 50/60Hz, AC110V 50/60Hz, AC220-240V 50/60Hz, AC380-415V 50/60Hz, DC24V, DC48V, DC110-120V, DC220V;
电动操作机构MOD23:
Us: AC110V 50/60Hz, AC220-240V 50/60Hz, AC380-415V 50/60Hz, DC24V, DC110V, DC220V.

联系人: 李然
电话: 021-37791111
电子邮箱: li.ran@noark.cn
指定签字人:

自我声明时间: 2023-07-06
自我声明地点: 上海

生产者签章:




强制性认证产品符合性自我声明(附页)



自我声明编号: 2020980307001431

产品系列、型号、规格(附件):

型号的解释:
Ex 9 M L 3 ◦
Ex: 企业特征代号
9: 企业设计序号
M: 空壳断路器通用代号
L: 剩余电流保护代号
3: 壳架电流代号: 3表示630A
◦: 分断能力代号: S, N, Q, H, P

联系人: 李然
电话: 021-37791111
电子邮箱: li.ran@noark.cn
指定签字人: 

自我声明时间: 2023-07-06

自我声明地点: 上海

生产者签章:



强制性认证产品符合性自我声明(附页)



自我声明编号: 2020980307001431

产品系列、型号、规格(附件):

Ex9ML3
Uimp: 12kV;
Ui: 1000V;
Ue: AC380/400/415V, AC440V;
In: 250A, 315A, 350A, 400A, 500A(TMU, Electromagnetic); 250A, 315A, 350A, 400A, 500A, 630A(ETU);
Over-current Release Type: TMU, Electromagnetic, ETU;
Ics=Icu:
AC380/400/415V: 36/50/70/100/150kA(S/N/Q/H/P);
AC440V: 36/50/70/100/100kA(S/N/Q/H/P);
Icw: 电子式: 5kA/1s(In<400A), 8kA/1s(In≥500A);
I=Icn: 0.03/0.05/0.1/0.2/0.3/0.5/1/2A. The eight gears are adjustable(0.03A is Non-delay type, the rest are non-delay, delay adjustable);
Rated residual operating current type: Type AC; Type A;
Rated current operating type: Electronic tripping;
I=Im: 25%/Icu;
Selectivity category: A(TMU, Electromagnetic), B(ETU);
Release level: 5, 10, 20, 30 Adjustable(SU20LM, SU20SM);
Poles: 3P, 4P;
Suitable for isolation:
50/60Hz;
Auxiliary contacts and alarm contacts:
(Auxiliary contacts AX21, Alarm contacts AL21, CQC Certificate number: CQC2019010304169161);
1N01NC;
Ith: 5A;
AC-15: Ue/In: AC110V/5A, AC240V/4A, AC415V/2A;
DC-13: Ue/In: DC110V/0.25A, DC220V/0.25A;
Electronic attachments in accordance with Appendix N;
Under Voltage Release UV722;
Us: AC48V 50/60Hz, AC110V 50/60Hz, AC220-240V 50/60Hz, AC380-415V 50/60Hz, DC24V, DC48V, DC110-120V, DC220V;
Shunt Release SHT22;
Us: AC48V 50/60Hz, AC110V 50/60Hz, AC220-240V 50/60Hz, AC380-415V 50/60Hz, DC24V, DC48V, DC110-120V, DC220V;
Motor operator MOD23;
Us: AC110V 50/60Hz, AC220-240V 50/60Hz, AC380-415V 50/60Hz, DC24V, DC110V, DC220V;

联系人: 李然
电话: 021-37791111
电子邮箱: li.ran@noark.cn
指定签字人:

自我声明时间: 2023-07-06

自我声明地点: 上海

生产者签章:

